

DIVISION OF INDUSTRY SERVICES
PO BOX 7162
MADISON WI 53707-7162
Contact Through Relay
http://dsps.wi.gov/programs/industry-services
www.wisconsin.gov

Scott Walker, Governor Dave Ross, Secretary

September 30, 2016

**Identification Numbers** 

Transaction ID No. 2763691 Site ID No.

Please refer to both identification numbers, above, in all correspondence with the agency.

CUST ID No. 1318826

PATRICK PFERSCH LANNON TANK CORPORATION 20134 W MAIN ST PO BOX 516 LANNON WI 53046

CONDITIONAL APPROVAL

PLAN APPROVAL EXPIRES: 09/30/2021

Re: Description: SEWAGE TANKS, STEEL

Manufacturer: LANNON TANK CORPORATION Product Name: (trans id 2763691) HOLDING Model Number(s): 3885 / H13M OR P-3 H13M

(60 IN. L.L.; 60 IN. MAX. DEPTH OF BURY, 4030 TOTAL GALLONS;

TANK DIMENSIONS = 291 IN. L X 65 IN. DIA. X 60 IN. H)

Product File No: 20160220

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of September 2021.** 

This approval supersedes the approval issued on 1/10/2012 under product file number 20120014.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The Smith and Loveless Versapox coating must be provided on all steel surfaces.
- The products produced by this manufacturer are approved to use the following:
  - Flip top access cover or bolt down cover with or without gasket.
  - 6", 8" or 10" threaded plug in access covers.
  - 4" vent connection in access cover.
  - 4" diameter suction pump extension with coupling.
  - 4" or 6" diameter inlet.
- For coatings of underground steel tanks, the following cathodic protection requirements will be provided by the manufacturer prior to leaving the plant, either:
  - 1. All exterior surfaces will be fiberglass coated; or
  - 2. All exterior surfaces will be polyurethane coated at the plant with either welded on or bolted on anodes.

**2763691** PATRICK PFERSCH Page 2 9/30/2016

BEDDING: Backfill material must be clean, homogeneous granular material comprised of sand, pea gravel, No. 8 crushed stones or equivalent. A 6-in. deep bed must be spread evenly over the dimensions off the pad. Tank must not be placed on any hard rock or sharp material. Sand backfill is used only when measures are taken to prevent any sand washout. Native backfill not containing any sharp objects may be used as backfill. In high water table areas, bedding material must be crushed stone or pea gravel.

• BACKFILL: Homogeneous backfill material similar to bedding material must be carefully placed around the entire tank to create a uniform homogeneous environment. When placing or tamping backfill, avoid damage to tank coatings. It is recommended that tamping backfill along the sides of the tank to insure the tank is fully and uniformly supported around the bottom quadrant.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. POWTS Product Reviewer phone: (608) 267-5265 fax: (608) 267-9723 email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction